

# Water Testing Report

Name **JAMMU SANSKRITI SCHOOL**

Village **ISMAILPUR KOTHEY NEAR SEMORA.** Source **BORE-WELL.**

Date **26-06-21.**

S.No.	Parameter	Result	Permissible Limit	Affects
1	Hardness	200	300 mg/L	affect stomach, skin irritation
2	Calcium	30	75 mg/L	affect kidney, bone deformities
3	Chloride	30	250 mg/L	affect blood circulation
4	Alkalinity	—	200 mg/L	affect stomach, skin irritation
5	Iron	0.0	0.3 mg/L	stomach problem / Constipation
6	Flouride	0.0	1.0 mg/L	dental / skelton fluorosis & non fluorosis
7	Chlorine	—	0.2 mg/L	carcinogenic (cancer causing) agents
8	Ph	7.3	6.5 - 8.5	skin problems, affect mucuos membrane, eye irritation
9	Nitrate	0.0	45 mg/L	blue baby syndrome in infants
10	Turbidity	—	5 NTU	affect stomach & kidney
11	Bacteria	—	-ve	Diarrhea, Dysentry, Typhoid Cholera


⑫ TDS  $\Rightarrow$  240

⑬ Phosphate  $\Rightarrow$  0.0

Remarks :- Water is SAFE. for drinking purposes.

  
Principal  
Jammu Sanskriti School  
Jammu.

  
Jammu Sanskriti School  
Ismailpur Kothey

  
Signature  
Lab Assistant

OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER  
SUB DIV BISHNAH; RURAL DIV JAMMU  
JAL SHAKTI DEPARTMENT

NO. S.O.B/151

Dt. 30-6-2021

Sr

The Principal Cum Vice-Chairperson  
Jammu Sanskriti School, Jammu.

Subject - Safe Water Drinking Certificate  
(sample submitted on 24-06-21 (BOREWELL))  
Reference - NO. JSS/2021-22/Lt. 82 Dt. 09-06-2021

Sir,

In reference to the subject cited above  
and reference quoted herein; the  
water sample submitted in the office of  
the undersigned and tested on  
26-06-21; the sample submitted  
is fit for drinking as on date  
of the issuance of this certificate (BOREWELL)  
(Certificate Enclosed)

A.E.E  
Sub Div BISHNAH

Asstt. Ex. Engineer  
PHE Sub-Division  
Bishnah

Principal  
Jammu Sanskriti School  
Jammu

Chairman  
Jammu Sanskriti School  
Ismailpur Kotley