

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Jammu Sanskriti School
Ismailpur Kothey, Near Seohra
Jammu

No: JDJF&ES/FP/3471

dated: 25/06.2023

Sub: Provisional Fire Safety Certificate,


Ref: Your Letter No. JSS/Lt. 21 dated: 09.06.2023

Sir,

The inspection of above said school was got carried out and found that the management has installed First Aid Fire Extinguishers in their school premises and are in working condition. Moreover, Hydrants are provided in four storied block but not functional at present. The school is about 04 Km away from Fire & Emergency Station Bishnah and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such the management can proceed ahead for operation provisionally subject to strictly adopt the following fire safety measures/guidelines in letter and spirit forthwith for the safety of students studying there:-

1. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. Hose Reel Hoses as per BIS specifications connected with the terrace tank of 5000 Ltrs. capacity should be provided in the both blocks. The Hose Reel Hose should be kept at such a place where from every nook and corner of each floor of both blocks are covered easily at the time of any emergency. A Fire Pump of desired capacity should be installed near underground water storage tank with dual electric supply for feeding the terrace tank.
3. 01 No. of CO₂ Type fire extinguisher of 4.5 Kg capacity should be provided near main electric switch board panel.
4. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the school building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments installed in the school are functioning.
5. If the basement existing in both blocks exceeded 200 m² then sprinkler should be there strictly as per NBC norms.
6. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
7. The corridor of the building shall not be used for any kind of storage.
8. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this provisional clearance issued will be treated withdrawn/cancelled.
9. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
10. At present school is having two blocks, in which one is four storied with basement and another is triple storied with basement. As such no addition / alteration should be made by the management in the existing structure without prior permission from this department. Any deviation found in this regard, this provisional clearance will be treated withdrawn/cancelled.
11. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
12. The validity of this provisional clearance shall remain in force for one year and final clearance shall be issued in favour of above said school only when the fire safety measures mentioned above are fully implemented by the management within stipulated period of time.

Yours Faithfully


Joint Director

Fire & Emergency Services

Jammu Range